



- NOTES**
- ALL DIMENSIONS ARE IN METRES UNLESS STATED OTHERWISE.
 - ALL WORK IS TO BE CARRIED OUT IN ACCORDANCE WITH THE SPECIFICATION FOR HIGHWAY WORKS AND LOCAL AUTHORITY GUIDANCE.
 - THIS DRAWING IS TO AID THE S104, S102, AND S106 APPLICATION TO SEVERN TRENT WATER.
 - ACCESS TO EXISTING PROPERTIES TO BE RETAINED AT ALL TIMES.
 - NO WORK SHOULD COMMENCE ON SITE UNTIL WRITTEN APPROVAL IS RECEIVED FROM THE ADOPTING HIGHWAY AUTHORITY. WORKS UNDERTAKEN PRIOR TO APPROVAL ARE AT THE CONTRACTORS RISK.
 - ALL INVERT LEVELS OF EXISTING FOUL AND SURFACE WATER SYSTEMS ARE TO BE CONFIRMED PRIOR TO THE COMMENCEMENT OF ANY ON SITE DRAINAGE WORKS. ANY DISCREPANCY IN LEVELS IS TO BE REPORTED IMMEDIATELY TO SCP.
 - FIRST PIPE OUT OF MANHOLES TO BE AS SHORT AS PRACTICABLE SO AS TO PROVIDE A FLEXIBLE JOINT AS CLOSE AS POSSIBLE TO THE OUTSIDE FACE OF THE CONCRETE SURROUND AND CONNECTED TO A ROCKER PIPE.
 - ANY DISCREPANCIES WITHIN THIS DRAWING PACKAGE ARE TO BE BROUGHT TO THE ATTENTION OF SCP TRANSPORT.
 - ALL DRAWINGS TO BE CHECKED BEFORE COMMENCEMENT OF WORK ON SITE.
 - ALL PIPE DIAMETERS GIVEN ARE NOMINAL INTERNAL PIPE DIAMETERS.
 - COVER SLABS MUST CARRY THE BSI KITEMARK AND SHALL COMPLY WITH BS 5911 PART 3 / BS EN 1917 2000. WHERE THE CLEAR OPENING OF THE KITEMARKED PRODUCT IS DIFFERENT TO THAT OF THE COVER AND FRAME, A LOAD BEARING SLAB SHOULD BE FITTED ABOVE THE COVER SLAB TO BRING THE SIZE DOWN TO 600MM X 600MM. PLEASE REFER TO CONCRETE PIPE ASSOCIATION (CPA) 'TECHNICAL BULLETIN' ISSUED AUTUMN 2004 FOR KITEMARKED COVER SLAB OPENING SIZES.
 - SULPHATE RESISTANT CEMENT (C20-DC2) AND PRECAST CONCRETE PRODUCTS MUST BE USED OR A LABORATORY REPORT PROVIDED TO PROVE THAT SUCH PRECAUTIONS ARE NOT REQUIRED.
 - ADOPTABLE SEWERS SHOULD BE A MINIMUM OF 1M AND MANHOLES 0.5M FROM KERB FACES AND SERVICE MARGINS, UNLESS OTHERWISE AGREED WITH THE SEWERAGE UNDERTAKER.
 - SEWERS MUST HAVE 5M CLEARANCE FROM TREES AND HEDGES WHERE POSSIBLE.
 - ALL PIPES TO HAVE CLASS 'S1' GRANULAR BED AND SURROUND UNLESS OTHERWISE STATED. BEDDING AND BACKFILL MATERIALS TO CONFORM TO THE REQUIREMENTS OF WIS 4-08-02 (TABLE A2), WHERE DEPTH OF COVER TO TOP OF SEWER IS LESS THAN 1.2M IN HIGHWAYS AND VERGES (OR LESS THAN 0.9M IN NONE VEHICULAR ACCESSED AREAS), THEN A 150MM THICK ST4 CONCRETE BED AND SURROUND SHALL BE PROVIDED.
 - ALL SEWER TRENCHES AND BRANCH CONNECTIONS TO BE BACKFILLED WITH SUITABLE MATERIAL IN LAYERS NOT EXCEEDING 225MM UNCONSOLIDATED THICKNESS THEN FULLY COMPACTED.
 - ADOPTABLE SEWER PIPES TO BE LAID IN MAXIMUM 3 METRE LENGTHS UNLESS THERE IS A SPECIFIC OPERATIONAL NEED TO LAY LONGER LENGTHS.
 - THE CHAMBER SIZE OF MANHOLES WITH MORE THAN ONE CONNECTION IN THEM MAY NEED TO BE INCREASED AN INCREMENT TO ACCOMMODATE THE CONNECTION AND BENDS - REFER TO MANHOLE SCHEDULE AND DETAILS FOR PIPEWORK ARRANGEMENT.
 - ALL ADOPTABLE SEWERS, UNLESS OTHERWISE STATED, SHALL BE UPVC PLASTIC PIPE.
 - FOR SURFACE WATER MANHOLE SCHEDULE REFER TO DRAWING 17109-0500-504.
 - FOR ATTENUATION POND DRAWING REFER TO DRAWING 17109-0500-506 AND 17109-0500-507.
 - ALL CHAMBERS TO BE PRECAST CONCRETE.
 - DRAWINGS ARE NUMBERED AS FOLLOWS: PHASE 1 17109-0500-101 PHASE 2 17109-0500-201 S106/S102 SURFACE WATER 17109-0500-301 S106/S102 FOUL WATER 17109-0500-302
 - ALL SURFACE AND FOUL WATER DRAINAGE IS DESIGNED AND TO BE CONSTRUCTED IN ACCORDANCE WITH SEWERS FOR ADOPTION 7th EDITION
 - INFILL COVERS AND FRAMES IN BLOCK PAVED AREAS ARE NOT TO BE USED (SEE 2.9.6 SFA6 P 25)
 - CATCHPIPS SHALL NOT BE ADOPTED.
 - WHERE PIPE CROSSING, PLASTIC MEMBRANE TO BE USED FOR PROTECTION TO ELIMINATE ANY CHANCES OF CROSS CONTAMINATION.
 - NO BACKDROPS TO BE USED, STEEPER GRADIENTS ARE PREFERRED TO THE USE OF BACKDROPS.
 - PRECAST CONCRETE MANHOLE RINGS WILL NOT BE CUT UNDER ANY CIRCUMSTANCES. OTHER OPTIONS ARE PREFERRED. MANHOLE BUILT UP WITH CONCRETE OR BRICK WORK TO THE TOP OF THE PIPE.
 - PROTECTIVE CONCRETE COVER SLABS TO BE USED ON PIPES IN NON TRAFFIC AREA WHICH DOESNT ACHIEVE 0.9m/900mm COVER LEVEL AND 1.2m/1200mm COVER IN TRAFFIC AREA.
 - PIPES OF DIFFERENT DIAMETERS ENTERING MANHOLES SHOULD BE INSTALLED WITH SOFFITS AT THE SAME LEVEL.
 - ALL PROPOSED MANHOLE COVERS & FRAMES AT A MINIMUM OF 675mm x 675mm TO MAINTAIN CLEAR OPENING AND TO COMPLY WITH SEVERN TRENT WATER LTD CURRENT HEALTH AND SAFETY STANDARDS.
 - THE MATERIALS TO BE USED ARE SUITABLE FOR THE GROUND CONDITIONS.
 - IN SITUATIONS WHERE TRAFFIC LOADING IS ANTICIPATED TO BE HEAVIER THAN WOULD OCCUR ON A TYPICAL RESIDENTIAL ESTATE DISTRIBUTOR ROAD (I.E BRAKING OR TURNING NEAR A JUNCTION) A HIGHER SPECIFICATION COVER (E600) SHOULD BE USED.
 - FOR SURFACE WATER MANHOLE SCHEDULE REFER TO DRAWING 17109-0500-504.
 - FOR ATTENUATION POND DRAWING REFER TO DRAWING 17109-0500-506 AND 17109-0500-507.

KEY

- EXISTING SURFACE WATER NETWORK
- EXISTING SURFACE MANHOLE
- - - EXISTING SURFACE WATER NETWORK TO BE ABANDONED
- EXISTING SURFACE MANHOLE TO BE ABANDONED
- PROPOSED SURFACE WATER TO BE ADOPTED BY SEVERN TRENT WATER
- PROPOSED SURFACE WATER MANHOLE
- THORESBY DEVELOPMENT SITE BOUNDARY
- S1.001 PIPE REFERENCE NUMBER FROM MICRO-DRAINAGE
- ADOPTABLE BOUNDARY
- 5m SEVERN TRENT WATER EASEMENT <300mm - 2.5m EASEMENT BOTH SIDES (5m) >300mm - 5m EASEMENT BOTH SIDES (10m)

THE SCP DESIGN COVERS THE INFRASTRUCTURE SURFACE WATER AND FOUL WATER DRAINAGE DESIGNS, FOR PHASE 1 AND 2 ONLY, WITH STUB PROVISIONS FOR FUTURE PHASES

HOUSE BUILDERS WILL DESIGN AND SUBMIT THEIR OWN SEPARATE PHASING SECTION 104 SUBMISSIONS, FOR SURFACE WATER AND FOUL WATER DRAINAGE DESIGNS, WHICH WILL NOT INCLUDE ANY UPSTREAM STORAGE SYSTEMS AND DISCHARGE/CONNECT INTO THE PHASING INFRASTRUCTURE SECTION 104 STORAGE TANKS AND POND SYSTEMS.

REVISIONS

REV	DESCRIPTION	DATE	BY
-	-	-	-
A	S104 DRAINAGE AMENDMENTS	19.07.18	OW

SCP
Transportation Planning : Infrastructure Design
Colwyn Chambers, 19 York Street, Manchester, M2 3BA, Tel 0161 832 4400, www.scptransport.co.uk, Email info@scptransport.co.uk

Client Name: HARWORTH ESTATES LTD

Project Title: THORESBY INFRASTRUCTURE DETAILED DESIGN

Drawing Title: S102 & S106 CONNECTIONS INTO EXISTING SURFACE WATER SEWER

Date: 18.04.2018 Drawn By: CW
Scale: 1:500 @ A1 1:1000 @ A3 Checked: WJ
Status: DESIGN Approved: UNAPPROVED

Drawing No: 17109-0500-301 Rev: A